



14 Julius Avenue, North Ryde NSW 2113  
PO Box 310, North Ryde NSW 1670, Australia  
T (02) 9490 5444 • ABN 41 687 119 230

13 June 2013

Our Ref: FCO-2998/CO4286

Bostik Australia Pty Ltd  
21 Tattersall Road  
KINGS PARK NSW 2148

Attention: Mr Steve Halpin

FIREBAN ONE FIRE RATED SEALANT MANUAL (ISSUE 2013 MAY 105544)  
Assessment No. FCO-2998

#### INTRODUCTION

We have examined the supplied document titled "Fireban One Fire Rated Sealant" (Issue numbered 2013 MAY 105544) with reference to the constructional specifications of various penetration and control joint systems as they relate to likely fire performance. We have retained a copy of this document. Other information assessed included:-

- Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2005, Fire-resistance tests of elements of building construction;
- Australian Standard 4072 Components for the protection of openings in fire-resistant separating elements, Part 1-2005, Service penetrations and control joints;
- CSIRO Sponsored Investigation test reports numbered FSP 0028, FSP 0035, FSP 0066, FSP 0070, FSP 0096, FSP 0188, FSP 0219, FSP 0222, FSV 0689, FSV 0690 and FSV 0691; and
- test report numbered FP 1819 from BRANZ.

Based on this information it is the opinion of the Division that the document represents systems consistent with our test data as capable of achieving the designated fire-resistance levels (FRL) in accordance with the requirements of the version of AS1530.4 in force at the time of testing.

#### TERM OF VALIDITY

This assessment report will lapse on 30 June 2018. Should you wish us to re-examine this report with a view to the possible extension of its term of validity, would you please apply to us three to four months before the date of expiry. This Division reserves the right at any time to amend or withdraw this assessment in the light of new knowledge.

Yours sincerely

A handwritten signature in blue ink that reads "B. Roddy". The signature is written in a cursive, flowing style.

Brett Roddy  
Fire Testing, Team Leader